TECHNICAL COMPLIANCE STATEMENT

This is to certify that the product listed below was (were) tested in the BTL EMC Laboratory to comply with below FCC official limits.

Equipment	**APM-EMA: Multi-Circuit Power Meter (DIN rail)** **APM-MAA: Current Input Module (Optional)**
Model Name	**APM-EMA, APM-MAA**
Brand Name	**ADTEK**
Applicant	**ADTEK ELECTRONICS CO., LTD.**
Address	**5F., No. 14, Lane 609, Sec. 5, Chongxin Rd., Sanchong Dist., New Taipei City 24159, Taiwan**
Standard(s)	**FCC CFR Title 47, Part 15, Subpart B Class A** **ICES-003, Issue 7, October 15, 2020 Class A** **ANSI C63.4-2014+C63.4a-2017**
Report(s)	**BTL-FCCE-1-2605T132**

The test data, data evaluation, and equipment configuration contained in our test report(s) above was (were) obtained utilizing the test procedures, test instruments, test sites that has been accredited by the Authority of TAF according to the ISO/IEC 17025 quality assessment standard and technical standard(s). The test data contained in the referenced test report relate only to the EUT sample and item(s) tested.

Pike Lee
Authorized Signatory

BTL INC.
No.18, Ln. 171, Sec. 2, Jiuzong Rd.,
Neihu Dist., Taipei City 114, Taiwan
TEL:+886-2-2657-3299
FAX:+886-2-2657-3331